

**AIR  
-&-  
GAS**

# CERTIFICATE OF ANALYSIS



**Lawrence Factor®**, Inc.  
4790 NW 157th Street  
Miami, FL 33014  
305-430-0550  
info@Lawrence-Factor.com  
www.Lawrence-Factor.com

TEST STANDARD(S): **CGA E (G-7.1, 2018)**


CLIENT FREQUENCY: **Single** ADVISED BY STANDARD: **Quarterly**

LAB SYSTEM:  In-Lab  LabOnLocale  LabOnLocale-Portable  LabOnLocale-OnBoard

ANALYTES	428723 7/7/2020	Allowable Limits	Pass Fail
Oxygen (%)	21.7	20 - 22	Pass
Nitrogen (%)	NA	NA	NA
Carbon Dioxide (ppm)	172.9	<1000	Pass
Carbon Monoxide (ppm)	ND	<10	Pass
Methane (ppm)	1.2	<25	Pass
Dew Point (°F)	-73	<-65	Pass
Water Vapor (ppm)	13.1	<24	Pass
Nitrogen Dioxide (ppm)	NA	NA	NA
Nitric Oxide (ppm)	NA	NA	NA
Sulfur Dioxide (ppm)	NA	NA	NA
Nitrous Oxide (ppm)	NA	NA	NA
THC (ppm)	NA	NA	NA
Halo.Solvents (ppm)	NA	NA	NA
VHC (ppm)	NA	NA	NA
VHHC (ppm)	NA	NA	NA
Oil & Particles (mg/m³)	0.041	<5	Pass
Odor	None	None	Pass
PASS or FAIL	Pass	NA	Pass

CLIENT	
NAME	Ontario County Emergency Management
ID	ONTA14424
LOCATION	
DESCRIPTION	
ADDRESS	
AIR SOURCE	
MAKE	
MODEL	
SN	
DESCRIPTION	EMO
NEXT TEST DATE	NA

Kit Number	428723	Certificate ID	42872307072000058656
Program Number	56177	Sampled	6/30/2020
Agent Name	JEROME FIRE EQUIPMENT	Received	7/7/2020
Agent ID	JERO14424	Analyzed	7/7/2020
Sample Collected By	BRETT KINDEL	Certificate Issued	7/7/2020
Notes			



*M. Silva*

Approved By Maria Silva

IMPORTANT: This air/gas or substance provided by the customer was analyzed against a specified standard and may contain undetected substances which are beyond the scope of the analysis requested by client. More extensive testing can be performed upon request. This analysis does not guarantee the current condition nor safe application of the analyzed air/gas or substance. Test results relate ONLY to the substances analyzed. This report contains information which may be confidential, privileged or protected. The information is intended only for the individual or entity named herein. If you are NOT the intended recipient, be aware that any disclosure, copying, distribution, or use of this information is prohibited. If you received this in error please notify us by phone. This report shall not be reproduced nor altered without written consent of the lab. Estimated Measurements of Uncertainty values for the reported analytes are available upon request. This certificate is not issued for an unbounded duration. ANALYTICAL METHODS USED: LF-500 – LF-507. TECHNOLOGIES USED: Infrared, electrochemical, color sensor, organoleptic.