


1 PARTIAL SITE & BASEMENT FLOOR PLAN
SCALE: 1" = 10'-0"



NOTE:
CONTRACTOR TO VERIFY LOCATIONS OF UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION. WHETHER SHOWN OR NOT. UNDERGROUND UTILITIES SHOWN IN THEIR RELATIVE POSITIONS ARE FOR INFORMATION ONLY. THEIR EXACT LOCATION SHALL BE CHECKED AT THE SITE BEFORE CONSTRUCTION BEGINS.

NOTE:
CONCRETE PANS FOR CONDENSERS C-1 & C-2 BY G.C.

SYMBOLS

CD	CONDENSATE DRAIN ABOVE GRADE (GROUND)
CD	CONDENSATE DRAIN BELOW GRADE (GROUND)
HWS	HOT WATER SUPPLY
MWR	MIXED WATER RETURN
CWS	CHILLED WATER SUPPLY
CHR	CHILLED WATER RETURN
R	REFRIGERANT PIPING
RVD	RELIEF VALVE DISCHARGE
MU	MAKE UP COLD WATER
CBV	CIRCUIT BALANCING VALVE
SDV	PUMP DISCHARGE VALVE STRAIGHT THRU
AV	PUMP DISCHARGE VALVE ANGLE
BV	BALL VALVE
GV	GLOBE VALVE
CV	CHECK VALVE
FCV	FLOW CHECK VALVE
BV	BUTTERFLY VALVE
BV	BUTTERFLY VALVE WITH MEMORY
DV	DRAIN VALVE/ HOSE BIB
TV	TWO WAY VALVE
TV	THREE WAY VALVE
EC	EXPANSION COMPENSATOR
PG	PIPE GUIDE
BV	BALL VALVE
BV	BALL VALVE WITH MEMORY
GC	GAS COCK
PTD	PIPE TURNED DN
PTU	PIPE TURNED UP

PA	PIPE ANCHOR
R	REDUCER
FC	FLEXIBLE CONNECTOR
U	UNION
WS	WATERPROOF SEAL
C	CLEANOUT
WC	WALL CLEANOUT
DC	DECK/ FLOOR CLEANOUT
T	THERMOSTAT - PROPORTIONAL HEATING ONLY
T	THERMOSTAT - ELECTRIC
T	THERMOSTAT - PROPORTIONAL
S	SENSOR - SEE DMS. & SPEC. FOR TYPE
S	SENSOR - HEAT FLOW
V	VALVE - SELF-CONTAINED
T	TIMER SWITCH
TM	THERMOMETER
P	PRESSURE GAUGE
PV	PRESSURE VACUUM GAUGE
FS	FLOW SWITCH
FAD	FIRE DAMPER & ACCESS DOOR
FSD	FIRE/ SMOKE DAMPER & ACCESS DOOR
VD	VOLUME DAMPER
ATV	ACOUSTICAL TURNING VANES
FC	FLEXIBLE CONNECTION
SIF	SPIN-IN FITTING WITH DAMPER
TC	TEMPERATURE CONTROL DAMPER
SAD	SUPPLY AIR DUCT
RAD	RETURN AIR DUCT
OAD	OUTSIDE AIR DUCT
EAD	EXHAUST AIR DUCT
BD	BACKDRAFT DAMPER

ABBREVIATIONS

DA	DAMPER
DC	DAMPER COMBUSTION AIR
FD	FIRE DAMPER & ACCESS DOOR
FSD	FIRE/SMOKE DAMPER & ACCESS DOOR
TC	TEMPERATURE CONTROL DAMPER
TD	TEMPERATURE DAMPER
CS	CENTRAL STATION UNIT
EF	EXHAUST FAN
F	FILTER
FC	FAN COIL
RH	RADIANT HEATER
RI	ROOF INTAKE
SD	SUCTION DIFFUSER
T	TANK
UH	UNIT HEATER
WR	WALL RADIATION
CD	CLEANOUT
DCD	DECK/FLOOR CLEANOUT
WCD	WALL CLEANOUT
AMF	AIR RELEASE FITTING
C	CONDENSER
CH	CHILLER
CSU	CENTRAL STATION UNIT
E	EXHAUST FAN
F	FILTER
FC	FAN COIL
RH	RADIANT HEATER
RI	ROOF INTAKE
SD	SUCTION DIFFUSER
T	TANK
UH	UNIT HEATER
WR	WALL RADIATION
FS	FLOW SWITCH
MS	MISCELLANEOUS EQUIPMENT
PS	PRESSURE SENSOR
PG	PRESSURE GAUGE
PV	PRESSURE VACUUM GAUGE
TM	THERMOMETER
AD	ACCESS DOOR
WH	WATER HEATER
CMR	CHILLED WATER RETURN
CWS	CHILLED WATER SUPPLY
CW	COLD WATER
CD	CONDENSATE DRAIN
G	GAS
MWR	HEATING WATER RETURN
HWS	HEATING WATER SUPPLY
RVD	RELIEF VALVE DRAIN
MU	MAKE UP WATER
W/S	WALL SLEEVE
WPS	WATERPROOF PIPE SEAL
BFP	BACKFLOW PREVENTER
BLV	BALL VALVE
BT/V	BUTTERFLY VALVE
CBV	CIRCUIT BALANCING VALVE
CK/V	CHECK VALVE
FCV	FLOW CHECK VALVE
GLV	GLOBE VALVE
GT/V	GATE VALVE
PRV	PRESSURE REGULATING VALVE
RV	RELIEF VALVE
SC	SELF-CONTAINED VALVE
SDV	PUMP DISCHARGE VALVE
CA	COMBUSTION AIR
CFM	CUBIC FEET PER MINUTE
CLG	CEILING
EA	EXHAUST AIR
EC	ELECTRICAL CONTRACTOR
FIN	FINISHED
FL	FLOOR
GA	GAUGE
GC	GENERAL CONSTRUCTION CONTRACTOR
GPW	GALLONS PER MINUTE
H	HEATING CONTRACTOR
HF	HEAT FLOW
HC	NORMALLY CLOSED
HO	NORMALLY OPEN
OA	OUTDOOR AIR
PC	PLUMBING CONTRACTOR
RA	RETURN AIR
SA	SUPPLY AIR
SC	SELF-CONTAINED
TC	TEMPERATURE CONTROL PANEL

2 PIPE TRENCH DETAIL
NO SCALE

RESTORATION OF
ONTARIO COUNTY COURT HOUSE
CANTON, NEW YORK

SCALE: AS SHOWN
COMMISSION NO. 1000
DRAWN BY: S.W.M., M.B.D.
DATE: APRIL 88
REVISED

DRAWING NO.

MEYER & MEYER ARCHITECTS
388 BROADWAY
ALBANY, NEW YORK 12207

MENDEL • MESICK • COHEN • WAITE • HALL • ARCHITECTS
ALBANY, NEW YORK 12207

PARTIAL SITE & BASEMENT FLOOR PLAN

DATE: APRIL 88
REVISED

